

CERTIFICATE OF DESIGN, INSTALLATION AND COMMISSIONING OF A FIRE DETECTION AND ALARM SYSTEM OF GRADE B, C, D, E OR F IN DOMESTIC PREMISES

Original (To the person ordering the work)

DETAILS OF THE CLIENT Issued in accordance with BS 5839-6 : 2013

Client: ABI DEVELOPMENTS LTD
 Address: EAST PLESTOR COTTAGE, THE PLESTOR, SELBORNE, HANTS, GU34 3JQ

DETAILS OF THE FIRE DETECTION AND ALARM SYSTEM The system is

Address: APARTMENT 1, FOREST GROVE HOUSE 10A LONDON ROAD, COLPURN, HANTS. PO8 8BX New:
 Extent of the fire detection and alarm system covered by this certificate: ENTIRE SYSTEM Modification:

DESCRIPTION OF SYSTEM GRADE AND SYSTEM CATEGORY Tick boxes as appropriate

System grade: B N/A C N/A D E N/A F N/A
 System category: LD1 N/A LD2 N/A LD3 PD1 N/A PD2 N/A

COMMISSIONING See Note 1 A tick in the box indicates the inspection or test has been performed and the results are **satisfactory**. N/A indicates an inspection or test is **Not Appropriate**

| | | | |
|---|---|--|---|
| Test buttons checked <input checked="" type="checkbox"/> | Simulated smoke or aerosol test <input checked="" type="checkbox"/> | Dedicated circuit(s) provided <input checked="" type="checkbox"/> | Sound level test instrument used <input checked="" type="checkbox"/> See Note 2 |
| All alarm warning devices operate <input checked="" type="checkbox"/> | Heat test <input checked="" type="checkbox"/> | Protective device labelled <input checked="" type="checkbox"/> | Model and serial No. <u>0830557</u> |
| Silencing system checked <input checked="" type="checkbox"/> | Bedroom sound level (Clause 13.2) <input checked="" type="checkbox"/> | Audible and visual indication of mains failure <input checked="" type="checkbox"/> | Serial No. of associated Electrical Installation Certificate or Minor Electrical Installation Works Certificate (See Note 1) <u>0378383</u> |

USER INSTRUCTIONS Tick boxes to indicate that the written information has been issued to the user

I/We the undersigned declare that the occupier* of the domestic premises (or owner in the case of a house in multiple occupancy) has been provided with written information about essential aspects of the operation and maintenance of the system, as follows:

| | | |
|--|---|---|
| Operation of the system <input checked="" type="checkbox"/> | Routine testing of the system <input checked="" type="checkbox"/> | Checking the system on reoccupation of the dwelling after a vacation etc. <input checked="" type="checkbox"/> |
| Action to be taken in the event of a fire alarm signal <input checked="" type="checkbox"/> | Servicing and maintenance of the system (including intervals at which any batteries should be replaced) <input checked="" type="checkbox"/> | The need to avoid contamination of detectors by paint <input checked="" type="checkbox"/> |
| Avoidance of false alarms and action in the event of a false alarm <input checked="" type="checkbox"/> | The need to keep clear space around all detectors and manual call points <input checked="" type="checkbox"/> | As-fitted drawing <input checked="" type="checkbox"/> |
| Warning that apparent false alarm from carbon monoxide detector may not be false alarm <input checked="" type="checkbox"/> | Special precautions relevant to any lithium batteries used in the system <input checked="" type="checkbox"/> | |

* In the case of a newly-built property, and where the future occupier is unknown, the User Instructions should be issued to the builder for onward transmission to the purchaser, together with the related electrical safety certificate.

CERTIFICATION OF DESIGN, INSTALLATION AND COMMISSIONING

I/We, being the person(s) responsible (as indicated by my/our signature(s) below), for the design, installation, and commissioning of the fire alarm system, particulars of which are set out above, CERTIFY that the said work for which I/we have been responsible complies to the best of my/our knowledge and belief with the recommendations of BS 5839: Part 6 for the system described above, except for the variations, if any, stated below:

Variations (if any) NONE

The extent of liability of the signatory is limited to the work described above as the subject of this certificate.

| | |
|--|---|
| For the DESIGN, INSTALLATION AND COMMISSIONING of the system: | This certificate has been reviewed by the Qualified Supervisor: |
| Signature <u>[Signature]</u> Date <u>22-9-18</u> | Signature <u>[Signature]</u> Date <u>22-9-18</u> |
| Name (CAPITALS) <u>NEIL DAVIS</u> | Name (CAPITALS) <u>NEIL DAVIS</u> |

DETAILS OF THE DOMESTIC INSTALLER

Trading Title: BRIGHTWAY ELECTRICAL LTD
 Address: 48 BURLINGTON ROAD PORTSMOUTH HANTS NICEIC Registration No (Essential information) 0113720
 Postcode: PO2 0DP

Note 1. The electrical safety aspects of the fire detection and alarm system must also be certified in accordance with BS 7671: 'Requirements for Electrical Installations' by issuing an electrical safety certificate of a form which meets the requirements of BS 7671, such as a 'Domestic Electrical Installation Certificate' or, where appropriate, a 'Minor Electrical Installation Works Certificate'.
 Note 2. An instrument complying with BS EN 61672, Class 2, with slow response and A weighting (see Clause 13.2), is suitable for measuring the sound level.
 Note 3. This certificate may be required by an authority responsible for enforcement of fire safety legislation, such as the building control authority or housing authority. The recipient of this certificate might rely on the certificate as evidence of compliance with legislation. Liability could arise on the part of any organization or person that issues a certificate without due care in ensuring its validity.

Please see the 'Notes for Recipient' on the reverse of this page.